

Subject: La Plata/Archuleta Water District Master Plan Review - CDOT Comments

From: "Horn, James B" <James.B.Horn@DOT.STATE.CO.US>

Date: Tue, 13 Apr 2010 15:01:23 -0600

To: "'info@laplawd.org'" <info@laplawd.org>

CC: "Cuthbert, Jo" <Jo.Cuthbert@DOT.STATE.CO.US>

Below are CDOT comments to this master plan:

1. An access permit is required for any direct access to the Highway
2. A Utility Permit is required for any utility work in CDOT ROW
3. CDOT requires utility crossings to be directional bores, not open trench cuts in the highway

Please let me know if you have any questions.....Jim

James B. Horn, P.E.
Traffic Resident Engineer
3803 N. Main Avenue, Suite 100
Durango, CO 81301
Ph: 970/385-3624
Fax: 970/385-8361
james.b.horn@dot.state.co.us